


ELEV. 04

TABELA DE CARACTERÍSTICAS TÉCNICAS CONDENSADORAS/EVAPORADORAS/TUBULAÇÕES

CONDENSADORA (externa)										EVAPORADORA (interna)			
Ambiente Contemplado	ITEM	POT (KW)	REF. FUJITSU	CAPAC.(BTU/s) Refr/Aquec	RUIDO (dB)	TUBO LIQ/GAS(mm)	DISTANCIA (cm)	ITEM	PESO (KG)	REFERENCIA FUJITSU	RUIDO (dB)	PESO (KG)	MODELO
QUARTO ACOLHIMENTO	01	1,13	220	ASBG12LMCA	12.900_15.300	50	6,35/9,52	631,32	01	26	ASBG12LMCA	21-43	8,6 HIGH WALL
QUARTO COLETIVO	02	1,13	220	ASBG12LMCA	12.900_15.300	50	6,35/9,52	522,07	02	26	ASBG12LMCA	21-43	8,6 HIGH WALL
QUARTO COLETIVO	03	1,13	220	ASBG12LMCA	12.900_15.300	50	6,35/9,52	511,60	03	26	ASBG12LMCA	21-43	8,6 HIGH WALL
QUARTO PLANTÃO	04	0,74	220	ASBG09LMCA	10.500_11.900	46	6,35/9,52	958,38	04	24	ASBG09LMCA	21-43	8,6 HIGH WALL
SALA CONVIVÊNCIA	05	2,31	220	ASBR24LFL	27.300_36.200	52	6,35/15,88	588,20	05	43	ASBA24LFC	32-47	14 HIGH WALL
SALA CONVIVÊNCIA	06	2,31	220	ASBR24LFL	27.300_36.200	52	6,35/15,88	829,77	06	43	ASBA24LFC	32-47	14 HIGH WALL
SALA ATENDIMENTO 1	07	1,13	220	ASBG12LMCA	12.900_15.300	50	6,35/9,52	811,72	07	26	ASBG12LMCA	21-43	8,6 HIGH WALL
SALA ATENDIMENTO 2	08	1,13	220	ASBG12LMCA	12.900_15.300	50	6,35/9,52	460,36	08	26	ASBG12LMCA	21-43	8,6 HIGH WALL
SALA ATENDIMENTO 3	09	1,13	220	ASBG12LMCA	12.900_15.300	50	6,35/9,52	238,15	09	26	ASBG12LMCA	21-43	8,6 HIGH WALL
ACOLHIMENTO	10	2,96	220	ACBA36LTL	9.200_43.300	54	9,52/15,88	332,39	10	61	ABBA36LCT	49-34	46 TETO INV
SALA ADMINISTRATIVO	11	1,13	220	ASBG12LMCA	12.900_15.300	50	6,35/9,52	379,20	11	26	ASBG12LMCA	21-43	8,6 HIGH WALL
SALA REUNIÕES	12	2,31	220	ASBR24LFL	27.300_36.200	52	6,35/15,88	598,07	12	43	ASBA24LFC	32-47	14 HIGH WALL
SALA ATIVIDADES 2	13	2,31	220	ASBR24LFL	27.300_36.200	52	6,35/15,88	598,07	13	43	ASBA24LFC	32-47	14 HIGH WALL
SALA ATIVIDADES 1	14	2,31	220	ASBR24LFL	27.300_36.200	52	6,35/15,88	523,05	14	43	ASBA24LFC	32-47	14 HIGH WALL
REFETORIO	15	2,31	220	ASBR24LFL	27.300_36.200	52	6,35/15,88	405,14	15	43	ASBA24LFC	32-47	14 HIGH WALL
REFETORIO	16	2,31	220	ASBR24LFL	27.300_36.200	52	6,35/15,88	857,55	16	43	ASBA24LFC	32-47	14 HIGH WALL
POSTO ENFERMAGEM	17	1,13	220	ASBG12LMCA	12.900_15.300	50	6,35/9,52	453,68	17	26	ASBG12LMCA	21-43	8,6 HIGH WALL
FARMACIA	18	1,13	220	ASBG12LMCA	12.900_15.300	50	6,35/9,52	430,36	18	26	ASBG12LMCA	21-43	8,6 HIGH WALL
QUARTO COLETIVO 2	19	1,13	220	ASBG12LMCA	12.900_15.300	50	6,35/9,52	392,58	19	26	ASBG12LMCA	21-43	8,6 HIGH WALL
QUARTO COLETIVO 1	20	1,13	220	ASBG12LMCA	12.900_15.300	50	6,35/9,52	396,51	20	26	ASBG12LMCA	21-43	8,6 HIGH WALL
QUARTO COLETIVO PNE 2	21	1,74	220	ADBR18LEC	20500_31000	51	6,35/12,70	620,24	21	40	ASBA18LEC	26-43	14 HIGH WALL
SALA TV	22	2,96	220	ADBA36LTL	9.200_43.300	54	9,52/15,88	1.166,15	22	61	ABBA36LCT	49-34	46 TETO INV
SALA JANTAR	23	2,31	220	ASBR24LFL	27.300_36.200	52	6,35/15,88	796,57	23	43	ASBA24LFC	32-47	14 HIGH WALL
ESCRTORIO	24	0,74	220	ASBG09LMCA	10.500_11.900	46	6,35/9,52	524,33	24	24	ASBG09LMCA	21-43	8,6 HIGH WALL
SALA ESTAR	25	2,96	220	ADBA36LTL	9.200_43.300	54	9,52/15,88	741,34	25	61	ABBA36LCT	49-34	46 TETO INV
QUARTO PLANTÃO	26	0,74	220	ASBG09LMCA	10.500_11.900	46	6,35/9,52	683,04	26	24	ASBG09LMCA	21-43	8,6 HIGH WALL
QUARTO COLETIVO 3	27	1,74	220	ADBR18LEC	20500_31000	51	6,35/12,70	473,15	27	40	ASBA18LEC	26-43	14 HIGH WALL
QUARTO COLETIVO 2	28	1,74	220	ADBR18LEC	20500_31000	51	6,35/12,70	430,34	28	40	ASBA18LEC	26-43	14 HIGH WALL
QUARTO COLETIVO 1	29	1,74	220	ADBR18LEC	20500_31000	51	6,35/12,70	458,61	29	40	ASBA18LEC	26-43	14 HIGH WALL
QUARTO COLETIVO PNE 1	30	1,74	220	ADBR18LEC	20500_31000	51	6,35/12,70	653,06	30	40	ASBA18LEC	26-43	14 HIGH WALL

LEGENDA - CONDENSADORAS E EVAPORADORAS



ELEV. 03

ELEV. 02

